



ठाणे महानगरपालिका
THE MUNICIPAL CORPORATION OF THE CITY OF THANE
प्रदूषण नियंत्रण कक्ष
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas ,Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 62
Sample No. : S15

Date : 13 April 2026

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S PES Global School

Address : Mith Bunder Road, Kopri, Thane(E) 400603

E_mail ID : PestKopri@gmail.com

Date of receiving Sample : 10 April 2026

Sample Collected by : Prabhakar Sonawale

Type of Water Sample : Storage Drinking (1st Sample)

Parameters	Results	Limits as per IS 10500
pH	7.20	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	2.0	5 NTU
Chloride	10.0	250 mg/L
Total Hardness	50.0	300 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

13-Apr-26

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

13-Apr-26

Nirmitee N. Salgaonkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (1st Sample) Water sample received to our Vakratunda Laboratory on 10/4/2026. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. /- vide Receipt No. dated

This Report Is Digitally Signed And Approved.